



Pollution Prevention – Grease Interceptor Maintenance Log

- Service Grease Interceptor **every month, at minimum**
- If Grease Interceptor is **more than 25% full, servicing is to be performed more frequently**
- Servicing includes **complete removal** of all solids and liquids
- Inspect Grease Interceptor while empty to ensure that the internal components such as baffles and walls are not corroded and are in good working order
- Do not use enzymes, solvents, hot water or any other agents to facilitate removal of Fat, Oil and Grease (FOG) through the Grease Interceptor

Establishment Name: _____

Address: _____

Phone: _____ Email: _____

Depth Measurement (cm)				% Full ((A+B) / C) * 100	Less than 25%?	Serviced? (Yes/No)	Serviced By (Company/Name/Invoice #)	Internal Inspection Comments (condition of baffles/walls, baffles present?)	Initials
Date	FOG (A)	Solids (B)	Total Depth (C)						

I certify that this document was prepared under my direction or supervision. The information is, to the best of my knowledge and belief, true, accurate and complete. All records of maintenance and cleaning shall be retained for 2 years. Failure to service the grease interceptor at minimum once a month or when 25% full, and to provide copies of the maintenance logs is a violation of Halifax Water's Rules and Regulations.

Name:		Title:	
Signature:		Date:	

After a Cleaning or Servicing please send a copy or picture of this form to grease@halifaxwater.ca or
Halifax Water Pollution Prevention, P.O. Box 8388 RPO CSC, Halifax, NS, B3K 5M1